



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.73				Y
2	OFF				OFF
3	OFF				OFF
4	7.74				Y
5	OFF				OFF
6	OFF				OFF
7	7.82	20			Y
8	OFF				OFF
9	OFF				OFF
10	7.83				Y
11	OFF				OFF
12	OFF				OFF
13	7.81				Y
14	OFF				OFF
15	7.76				Y
16	OFF				OFF
17	OFF				OFF
18	7.70				Y
19	OFF				OFF
20	OFF				OFF
21	7.68				Y
22	OFF				OFF
23	OFF				OFF
24	7.77	20			Y
25	OFF				OFF
26	OFF				OFF
27	7.76				Y
28	OFF				OFF

(No = N = Excursion) Total N's

County: Marion Agency: Region I
ENTRY POINT
PWS ID: 41
System Name: GATES, CITY OF
Entry Point: EP-A
Sample Period: FEBRUARY / 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.3"/>	
Alk	<input type="text" value="19"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Sili	<input type="text"/>	(Silicate)

Print Name: GREGORY R BENTHIN
Signature: Gregory R Benthin
Date: 3-1-21

Send to DWP within 10 days after end of sampling period