



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	OFF				OFF
2	7.92				Y
3	OFF				OFF
4	8.04				Y
5	OFF				OFF
6	OFF				OFF
7	8.04	20			Y
8	OFF				OFF
9	OFF				OFF
10	8.12				Y
11	OFF				OFF
12	OFF				OFF
13	8.20				Y
14	OFF				OFF
15	OFF				OFF
16	8.04				Y
17	OFF				OFF
18	OFF				OFF
19	7.89				Y
20	OFF				OFF
21	OFF				OFF
22	7.78	20			Y
23	OFF				OFF
24	7.85				Y
25	OFF				OFF
26	OFF				OFF
27	7.81				Y
28	OFF				OFF
29	OFF				OFF
30	8.04				Y
31	OFF				OFF

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day? County: Marion Agency: Region I

ENTRY POINT

PWS ID: 41 0 0 3 1 7

System Name: GATES, CITY OF

Entry Point: EP-A

Sample Period: MARCH / 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by

pH	7.3	
Alk	19	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: GREGORY R BENTON

Signature: Gregory R Benton

Date: 4-5-2021

Send to DWP within 10 days after end of sampling period