



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	OFF				OFF
2	8.15				Y
3	OFF				OFF
4	OFF				OFF
5	8.10				Y
6	OFF				OFF
7	OFF				OFF
8	8.0	20			Y
9	OFF				OFF
10	OFF				OFF
11	8.18				Y
12	OFF				OFF
13	8.05				Y
14	OFF				OFF
15	OFF				OFF
16	8.24				Y
17	OFF				OFF
18	7.72				Y
19	OFF				OFF
20	8.31				Y
21	OFF				OFF
22	OFF				OFF
23	8.35				Y
24	OFF				OFF
25	OFF				OFF
26	8.28	20			Y
27	OFF				OFF
28	OFF				OFF
29	8.35				Y
30	OFF				OFF

County: Marion Agency: Region 1
ENTRY POINT
 <<Have minimums been met for this day? PWS ID: 41 0 0 3 1 7
 System Name: GATES, CITY OF
 Entry Point: EP-A
 Sample Period: April/2021
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by

pH	7.3	
Alk	19	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: GREGORY R BENTHIN
 Signature: Greg R Benthin
 Date: 5-4-2021

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0