



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	OFF				OFF
2	7.82				Y
3	OFF				OFF
4	OFF				OFF
5	8.25				Y
6	8.05				Y
7	OFF				OFF
8	7.80				Y
9	OFF				OFF
10	OFF				OFF
11	8.23				Y
12	8.27	20			Y
13	8.20				Y
14	8.06				Y
15	7.96				Y
16	OFF				OFF
17	8.22				Y
18	OFF				OFF
19	8.18				Y
20	OFF				OFF
21	OFF				OFF
22	8.14				Y
23	OFF				OFF
24	OFF				OFF
25	8.22				Y
26	OFF				OFF
27	OFF				OFF
28	8.16	20			Y
29	OFF				OFF
30	OFF				OFF
31	OFF				OFF

County: Marion Agency: Region I
ENTRY POINT
 <<Have minimums been met for this day? PWS ID: 41 0 0 3 1 7
 System Name: GATES, CITY OF
 Entry Point: EP-A
 Sample Period: May/2021
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by

pH	7.3	
Alk	19	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: GREGORY R BENTHAM
 Signature: Gregory R Bentham
 Date: 6-4-21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0