



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.31	20			Y
2	7.75				Y
3	OFF				OFF
4	8.06				Y
5	7.91				Y
6	OFF				OFF
7	8.22				Y
8	OFF				OFF
9	OFF				OFF
10	8.10				Y
11	OFF				OFF
12	OFF				OFF
13	7.44				Y
14	7.42	10			Y
15	OFF				OFF
16	8.22				Y
17	8.13				Y
18	8.18				Y
19	OFF				OFF
20	8.30				Y
21	8.21				Y
22	8.04				Y
23	8.07				Y
24	8.15				Y
25	7.81				Y
26	7.82				Y
27	OFF				OFF
28	8.14				Y
29	7.60				Y
30	7.62				Y

County: Marion Agency: Region I

ENTRY POINT

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 0 0 3 1 7

System Name: GATES, CITY OF

Entry Point: EP-A

Sample Period: June 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by

pH 7.3

Alk 19 (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: GREGORY R BENTHIN

Signature: *Gregory R Benthin*

Date: 7-1-2021

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0