



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.09				Y
2	OFF				OFF
3	7.87				Y
4	7.64				Y
5	7.70				Y
6	7.78	24			Y
7	7.80				Y
8	8.01				Y
9	OFF				OFF
10	8.05				Y
11	7.64				Y
12	8.07				Y
13	7.86				Y
14	7.94				Y
15	7.48				Y
16	8.11				Y
17	7.82				Y
18	7.88				Y
19	8.05				Y
20	8.04	24			Y
21	OFF				OFF
22	8.03				Y
23	8.12				Y
24	7.97				Y
25	8.11				Y
26	7.95				Y
27	OFF				OFF
28	7.92				Y
29	8.15				Y
30	8.02				Y
31	8.04				Y

County: Marion      Agency: Region I  
**ENTRY POINT**  
 <<Have minimums been met for this day?      PWS ID: 41 0 0 3 1 7  
 System Name: GATES, CITY OF  
 Entry Point: EP-A  
 Sample Period: July / 2021  
Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by**

pH	7.3	
Alk	19	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: GREGORY R BENTHIN  
 Signature: Gregory R Benthin  
 Date: 8-2-2021

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0