



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.56				Y
2	8.14				Y
3	7.96	24			Y
4	8.15				Y
5	7.94				Y
6	off				off
7	7.80				Y
8	7.79				Y
9	2.97				Y
10	7.92				Y
11	7.75	24			Y
12	7.39				Y
13	7.83				Y
14	7.38				Y
15	7.51				Y
16	7.69	20			Y
17	7.70				Y
18	off				off
19	7.90				Y
20	off				off
21	7.70				Y
22	off				off
23	7.55	25			Y
24	OFF				off
25	7.95				Y
26	OFF				off
27	7.65				Y
28	OFF				off
29	8.36				Y
30	OFF				off
31	7.98	24			Y

County: Marion Agency: Region I
ENTRY POINT
 <<Have minimums been met for this day? PWS ID: 41 0 0 3 1 7
 System Name: GATES, CITY OF
 Entry Point: EP-A
 Sample Period: August / 2021
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by	
pH	7.3
Alk	19 (Alkalinity)
PO4	(Orthophosphate)
Sili	(Silicate)

Print Name: GREGORY R BENTIN
 Signature: Greg R Bentin
 Date: 8-1-21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0