



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	off				off
2	7.95				Y
3	off				off
4	7.43				Y
5	off				off
6	8.25				Y
7	off				off
8	7.43	24			Y
9					off
10	7.45				Y
11					off
12	7.66				Y
13					off
14	7.71	22			Y
15					off
16	7.66				Y
17					off
18	7.62				Y
19					off
20	7.67				Y
21					off
22	7.75	20			Y
23					off
24	7.87				Y
25					off
26					off
27	7.66	24			Y
28	off				off
29	off				off
30	7.81				Y

County: Marion Agency: Region I
ENTRY POINT
 <<Have minimums been met for this day? PWS ID: 41 0 0 3 1 7
 System Name: GATES, CITY OF
 Entry Point: EP-A
 Sample Period: SEPT / 2021
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by
 pH 7.3
 Alk 19 (Alkalinity)
 PO4 (Orthophosphate)
 Sili (Silicate)

Print Name: GREGORY R BENTON
 Signature: *Gregory R Benton*
 Date: 10-4-2021

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0