



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.77				Y
2	off				off
3	7.79				Y
4	off				off
5	off				off
6	7.87				Y
7	off				off
8	off				off
9	8.34				Y
10	off				off
11	off				off
12	7.94	25			Y
13	off				off
14	off				off
15	7.90				Y
16	off				off
17	off				off
18	8.06	24			Y
19	off				off
20	off				off
21	7.94				Y
22	off				off
23	off				off
24	8.06				Y
25	8.02	24			Y
26	off				off
27	off				off
28	7.95				Y
29	off				off
30	off				off
31	8.18				Y

(No = N = Excursion) Total N's 0

County: Marion Agency: Region I
ENTRY POINT
 <<Have minimums been met for this day? PWS ID: 41 00317
 System Name: GATES, CITY OF
 Entry Point: EP-A
 Sample Period: OCTOBER/2021
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by

pH	7.3	
Alk	19	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: GREGORY R BENTHIN
 Signature: Gregory R Benthin
 Date: 11-1-2021

Send to DWP within 10 days after end of sampling period