



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	off				off
2	off				off
3	7.93	26			Y
4	off				off
5	off				off
6	8.10				Y
7	off				off
8	off				off
9	7.85	25			Y
10	off				off
11	off				off
12	7.73				Y
13	off				off
14	off				off
15	7.68	25			Y
16	off				off
17	off				off
18	7.82				Y
19	off				off
20	off				off
21	7.91				Y
22	off				off
23	off				off
24	7.96	25			Y
25	off				off
26	off				off
27	off				off
28	off				off
29	off				off
30	7.75				Y

County: Marion Agency: Region I  
**ENTRY POINT**  
 <<Have minimums been met for this day?  
 PWS ID: 41 0 0 3 1 7  
 System Name: GATES, CITY OF  
 Entry Point: EP-A  
 Sample Period: November / 2021  
Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by**

pH	7.3	
Alk	19	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: GREGORY R BENTHIN  
 Signature: [Signature]  
 Date: 12-3-21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0