



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.79				Y
2	off				off
3	off				off
4	7.72	22			Y
5	off				off
6	off				off
7	7.60				Y
8	off				off
9	7.75				Y
10	off				off
11	off				off
12	7.76	24			Y
13	7.64				Y
14	off				off
15	7.65				Y
16	off				off
17	off				off
18	7.72	21			Y
19	7.67				Y
20	off				off
21	7.68				Y
22	off				off
23	7.81				Y
24	off				off
25	off				off
26	7.76	24			Y
27	off				off
28	off				off
29	7.75				Y
30	off				off
31	off				off

County: Marion Agency: Region I  
**ENTRY POINT**  
 <<Have minimums been met for this day?  
 PWS ID: 41 0 0 3 1 7  
 System Name: GATES, CITY OF  
 Entry Point: EP-A  
 Sample Period: JANUARY / 2022  
Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by**

pH	7.3	
Alk	19	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: GREGORY R BENTHIN  
 Signature: Greg R Benthin  
 Date: 2-1-2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0