



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.37				Y
2	off				off
3	off				off
4	8.18	22			Y
5	off				off
6	off				off
7	8.17	22			Y
8	off				off
9	off				off
10	8.18				Y
11	off				off
12	off				off
13	8.30				Y
14	off				off
15	off				off
16	8.37	22			Y
17	off				off
18	8.06				Y
19	off				off
20	8.33				Y
21	off				off
22	8.33	24			Y
23	8.21				Y
24	8.19				Y
25	off				off
26	8.48				Y
27	off				off
28	off				off

County: Marion Agency: Region 1
ENTRY POINT
 <<Have minimums been met for this day? PWS ID: 41 0 0 3 1 7
 System Name: GATES, CITY OF
 Entry Point: EP-A
 Sample Period: FEBRUARY / 2022 63
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by

pH	7.3	
Alk	19	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: GREGORY R BENTON
 Signature: *Greg R Benton*
 Date: 3-4-2022 63

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0