



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.71				Y
2	off				off
3	off				off
4	8.38				Y
5	off				off
6	off				off
7	8.77	22			Y
8	off				off
9	off				off
10	8.81				Y
11	off				off
12	8.99				Y
13	off				off
14	off				off
15	8.48	24			Y
16	8.31				Y
17	off				off
18	8.68				Y
19	off				off
20	off				off
21	8.72	24			Y
22	off				off
23	off				off
24	8.59				Y
25	off				off
26	8.84				Y
27	off				off
28	8.83	24			Y
29	off				off
30	off				off
31	8.70				Y

<<Have minimums been met for this day?

County: Marion Agency: Region 1

ENTRY POINT

PWS ID: 41

System Name: GATES, CITY OF

Entry Point: EP-A

Sample Period: MARCH / 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by

pH
Alk (Alkalinity)
PO4 (Orthophosphate)
Sili (Silicate)

Print Name: GREGORY R BENTHIN
Signature: Gregory R Benthin
Date: 4-1-2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's