

Day	pH	Alk	Phos	Other	Y/N
1	off				off
2	off				off
3	8.77				Y
4	off				off
5	off				off
6	8.83	24			Y
7	off				off
8	off				off
9	8.83				Y
10	off				off
11	off				off
12	8.82				Y
13	off				off
14	off				off
15	8.74	16			Y
16	off				off
17	off				off
18	8.85	24			Y
19	off				off
20	off				off
21	8.35				Y
22	off				off
23	off				off
24	8.14				Y
25	off				off
26	off				off
27	8.31	24			Y
28	off				off
29	off				off
30	9.02				Y
31					

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: City of Gates

Entry Point: EP-A (EP for North Santiam River)

Sample Period: April / 2022
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.3"/>	
Alk	<input type="text" value="19"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Other	<input type="text"/>	(_____)

Print Name: GREGORY R BENTHIN

Signature: Greg R Benthin

Date: 5-3-2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's