

Day	pH	Alk	Phos	Other	Y/N
1	off				off
2	off				off
3	8.56				Y
4	off				off
5	off				off
6	8.66	24			Y
7	off				off
8	off				off
9	8.64	20			Y
10	off				off
11	off				off
12	7.95				X
13	off				off
14	off				off
15	8.29				Y
16	off				off
17	off				off
18	7.97	22			Y
19	off				off
20	off				off
21	8.13				Y
22	off				off
23	8.03				X
24	off				off
25	8.08	22			Y
26	off				off
27	off				off
28	8.20				Y
29	off				off
30	off				off
31	8.25				Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	3	1	7
---	---	---	---	---

System Name: City of Gates

Entry Point: EP-A (EP for North Santiam River)

Sample Period: MAY / 2022
Month/Year

Number of excursions* during this month: 8
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 8
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.3	
Alk	19	(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

Print Name: GREGORY R BENTHIN

Signature: Gregory R Benthin

Date: 6-1-22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's

8
