



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	off				off
2	off				off
3	8.43	28			Y
4	off				off
5	off				off
6	8.30	24			Y
7	off				off
8	off				off
9	8.55				Y
10	off				off
11	off				off
12	8.30				Y
13	off				off
14	off				off
15	7.98				Y
16	off				off
17	off	22			off
18	8.40				Y
19	off				off
20	off				off
21	8.24				Y
22	off				off
23	off				off
24	8.08				Y
25	off				off
26	8.30				Y
27	off				off
28	7.80				Y
29	off				off
30	8.32	24			Y

County: Marion Agency: Region I
ENTRY POINT
 <<Have minimums been met for this day? PWS ID: 41 0 0 3 1 7
 System Name: GATES, CITY OF
 Entry Point: EP-A
 Sample Period: JUNE / 2022
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by

pH	7.3	
Alk	 	(Alkalinity)
PO4	 	(Orthophosphate)
Sili	 	(Silicate)

Print Name: GREGORY R BENTHIN
 Signature: [Signature]
 Date: 7-5-22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0