

Day	pH	Alk	Phos	Other	Y/N
1	8.43				Yes
2	8.63				Yes
3	8.33	20			Yes
4	8.31				Yes
5	8.31				Yes
6	Off				Off
7	8.27				Yes
8	8.37				Yes
9	8.27				Yes
10	8.66				Yes
11	8.55	22			Yes
12	Off				Off
13	8.73				Yes
14	8.86				Yes
15	8.43				Yes
16	8.29				Yes
17	8.47				Yes
18	8.40	19			Yes
19	8.38				Yes
20	Off				Off
21	8.65				Yes
22	8.58	20			Yes
23	8.31				Yes
24	8.35				Yes
25	Off				Off
26	8.68				Yes
27	8.74				Yes
28	8.72				Yes
29	8.48				Yes
30	8.37				Yes
31	8.65				Yes
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

0	0	3	1	7
---	---	---	---	---

System Name: GATES, CITY of

Entry Point: EP-A

Sample Period: August / 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.3

Alk

19

 (Alkalinity)

PO4

--

 (Orthophosphate)

Other

--

 (_____)

Print Name: Gregory R Benthin

Signature: *Gregory R Benthin*

Date: September 1, 2022

Send to DWP within 10 days after end of sampling period