



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.28				Y
2	8.29				Y
3	8.38				Y
4					OFF
5	8.28	21			Y
6	8.17				Y
7	8.21				Y
8	8.01				Y
9	8.26				Y
10	8.20				Y
11	8.34				Y
12	8.11	22			Y
13					OFF
14	8.23				Y
15					OFF
16	8.53				Y
17					OFF
18	8.45				Y
19	8.77				Y
20	8.34				Y
21					OFF
22	8.51	22			Y
23	8.21				Y
24	8.26				Y
25					OFF
26	8.21				Y
27	8.39				Y
28	8.29				Y
29	8.16				Y
30					OFF

County: Marion Agency: Region 1
ENTRY POINT
 <<Have minimums been met for this day? PWS ID: 41 00317
 System Name: GATES, CITY OF
 Entry Point: EP-A
 Sample Period: SEPT / 2022
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by

pH	7.3	
Alk	19	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: GREGORY R BENTHIN
 Signature: [Signature]
 Date: 10-5-2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0