

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.24				Y
2	Off				Off
3	8.21				Yes
4	8.01				Yes
5	8.02	24			Yes
6	Off				Off
7	8.04				Yes
8	8.12				Yes
9	Off				Yes
10	7.96				Yes
11	7.91				Yes
12	Off				Off
13	7.97				Yes
14	7.97				Yes
15	7.95				Yes
16	Off				Off
17	8.07				Yes
18	8.07				Yes
19	7.91	24			Yes
20	Off				Off
21	8.07				Yes
22	Off				Off
23	8.31				Yes
24	Off				Off
25	8.27				Yes
26	Off				Off
27	8.15	28			Yes
28	Off				Off
29	8.22				Yes
30	Off				Off
31	8.33	23			Yes
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 

0	0	3	1	7
---	---	---	---	---

System Name: GATES, CITY of

Entry Point: EP-A

Sample Period: Oct-2022  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH 

7.3
-----

Alk 

19
----

 (Alkalinity)

PO4 

--

 (Orthophosphate)

Other 

(_____)
---------

Print Name: Gregory R Benthin

Signature: *Gregory R Benthin*

Date: 11/2/2022

Send to DWP within 10 days after end of sampling period