

Day	pH	Alk	Phos	Other	Y/N
1	Off				Yes
2	8.45				Yes
3	8.39				Yes
4	Off				Off
5	8.57				Yes
6	8.53				Yes
7	Off	22			Yes
8	8.26				Yes
9	8.42				Yes
10	8.29				Yes
11	8.15				Yes
12	Off				Off
13	8.36				Yes
14	8.03				Yes
15	8.41				Yes
16	8.37				Yes
17	Off				Off
18	8.33				Yes
19	8.13	24			Yes
20	Off				Off
21	8.38				Yes
22	Off				Off
23	Off				Off
24	8.44				Yes
25	Off				Off
26	Off				Off
27	8.48				Yes
28	Off				Off
29	Off				Off
30	8.49	22			Yes
31					
					0

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 

0	0	3	1	7
---	---	---	---	---

**System Name:** Gates, City off

**Entry Point:** EP-A

**Sample Period:** November/2022  
*Month/Year*

**Number of excursions\* during this month: 0**  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months: 0**  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 

7.3
-----

Alk 

19
----

*(Alkalinity)*

PO4 

--

*(Orthophosphate)*

Other 

--

*(\_\_\_\_\_)*

**Print Name:** Gregory R Benthin

**Signature:** *Gregory R Benthin*

**Date:** December 1, 2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**