

Day	pH	Alk	Phos	Other	Y/N
1					Off
2	8.49				Y
3					Off
4					Off
5	8.40				Y
6					Off
7					Off
8	8.33	24			Y
9	8.26				Y
10					Off
11	8.37				Y
12	8.29				Y
13					Off
14	8.44				Y
15					Off
16		24			Off
17	8.36				Y
18					Off
19					Off
20	8.37				Y
21					Off
22					Off
23	8.46	24			Y
24	8.40				Y
25					Off
26	8.31				Yes
27					Off
28					Off
29	8.15	24			
30					Off
31					Off
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

0	0	3	1	7
---	---	---	---	---

System Name: GATES, CITY of

Entry Point: EP-A

Sample Period: December/2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.3

Alk

19

(Alkalinity)

PO4

--

(Orthophosphate)

Other

--

(_____)

Print Name: Gregory R Benthin

Signature: *Gregory R Benthin*

Date: 1/3/2023

Send to DWP within 10 days after end of sampling period