



Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.35				Y
2	8.20				Y
3					Off
4	8.30				Y
5					Off
6					Off
7	8.34				Y
8	8.18				Y
9					Off
10					Off
11	8.38				Y
12					Off
13		20			Off
14	8.24				Y
15					Off
16					Off
17	8.31				Y
18	8.15				Y
19					Off
20		22			
21					Off
22					Off
23	8.28				Y
24					Off
25					Off
26	8.33	24			Y
27					Off
28					Off
29	8.30				Y
30					Off
31					Off

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	3	1	7
---	---	---	---	---

System Name: Gates, City of

Entry Point: EP-A

Sample Period: January 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.30

Alk

19

 (Alkalinity)

PO4

--

 (Orthophosphate)

Other

--

 (_____)

Print Name: Gregory R Benthin

Signature: *Gregory R Benthin*

Date: 2/1/2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's | 0