

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.29				Y
2					Off
3					Off
4	8.34				Y
5					Off
6					Off
7	8.38				Y
8					Off
9					Off
10	8.38				Y
11					Off
12					Off
13	8.21	24			Y
14					Off
15					Off
16	8.35				Y
17					Off
18					Off
19	8.45				Y
20					Off
21		28			Off
22	8.42				Y
23	8.25	22			Y
24					Off
25					Off
26	8.49				Y
27					Off
28		28			Off
29					
30					
31					
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 

0	0	3	1	7
---	---	---	---	---

System Name: Gates, City of

Entry Point: EP-A

Sample Period: February/2023  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH 

7.30
------

Alk 

19
----

 (Alkalinity)

PO4 

--

 (Orthophosphate)

Other 

--

 (\_\_\_\_\_)

Print Name: Gregory R Benthin

Signature: *Gregory R Benthin*

Date: 3/1/23

Send to DWP within 10 days after end of sampling period