

**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	8.46				Y
2					Off
3		22			Off
4	8.60				Y
5					Off
6					Off
7	8.69				Y
8		26			Off
9					Off
10	8.64				Y
11					Off
12					Off
13	8.82				Y
14					Off
15					Off
16	8.73				Y
17	8.51				Y
18					Off
19	8.65				Y
20	8.57				Y
21		22			Off
22	8.64				Y
23					Off
24					Off
25	8.61				Y
26	8.29				Y
27					Off
28	8.61				Y
29	8.29				Y
30					Off
31					Off
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 

0	0	3	1	7
---	---	---	---	---

System Name: Gates, City of

Entry Point: EP-A

Sample Period March-2023  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH 

7.30
------

Alk 

19
----

 (Alkalinity)

PO4 

--

 (Orthophosphate)

Other 

--

 (\_\_\_\_\_)

Print Name: Gregory R Benthin

Signature: *Gregory R Benthin*

Date: 4/5/2023

Send to DWP within 10 days after end of sampling period