

Day	pH	Alk	Phos	Other	Y/N
1	8.58				Y
2	8.45				Y
3					Off
4		26			Off
5	8.48	24			Y
6					Off
7					Off
8					Off
9	8.66				Y
10	8.55				Y
11					Off
12		24			Off
13	8.46				Y
14					Off
15					Off
16					Off
17	8.67	22			Y
18	8.43				Y
19					Off
20					Off
21	8.67				Y
22					Off
23					Off
24					Off
25	8.66	22			Y
26	8.41				Y
27					Off
28					Off
29	8.77				Y
30					Off
					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	3	1	7
---	---	---	---	---

System Name: Gates, City of

Entry Point: EP-A

Sample Period: April 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<table border="1"><tr><td>7.30</td></tr></table>	7.30	
7.30			
Alk	<table border="1"><tr><td>19</td></tr></table>	19	(Alkalinity)
19			
PO4	<table border="1"><tr><td></td></tr></table>		(Orthophosphate)
Other	<table border="1"><tr><td></td></tr></table>		(_____)

Print Name: Gregory R Benthin

Signature: 

Date: 5/2/23

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**