

Day	pH	Alk	Phos	Other	Y/N
1					Off
2					Off
3	8.78				Y
4	8.68				Y
5		20			Off
6					Off
7	8.71				Y
8					Off
9					Off
10					Off
11	8.70	28			Y
12					Off
13					Off
14	8.59				Y
15	8.48				Y
16					Off
17	8.45				Y
18	8.15				Y
19	8.59	20			Y
20					Off
21	8.76				Y
22	8.40				Y
23					Off
24	8.54				Y
25	8.27				Y
26	8.59	30			Y
27					Off
28	8.85				Y
29	8.37				Y
30	8.75				Y
31					Off
					0

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 

0	0	3	1	7
---	---	---	---	---

System Name: Gates, City of

Entry Point: EP-A

Sample Period: May 2023  
*Month/Year*

Number of excursions\* during this month: 0  
*(Count the number of days when any WQP was less than the minimum required)*

Total excursions during the previous 5 months: 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 

7.30
------

Alk 

19
----

*(Alkalinity)*

PO4 

--

*(Orthophosphate)*

Other 

--

*(\_\_\_\_\_)*

Print Name: Gregory R Benthin

Signature: *Gregory R Benthin*

Date: 6/5/2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**