

Day	pH	Alk	Phos	Other	Y/N
1	8.68				Y
2	8.68				Y
3	8.53	22			Y
4	8.43				Y
5	8.58				Y
6					Off
7	8.66				Y
8					Off
9	8.58				Y
10	8.58				Y
11	8.45				Y
12	8.55	24			Y
13	8.43				Y
14	8.26				Y
15	8.30				Y
16	8.27				Y
17	8.47	22			Y
18	8.39				Y
19	8.56				Y
20	8.42				Y
21	8.30				Y
22					Off
23	8.47				Y
24	8.45				Y
25	8.60	26			Y
26					Off
27	8.81				Y
28	8.44				Y
29	8.63				Y
30	8.35				Y
31	8.29	26			Y
					0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

0	0	3	1	7
---	---	---	---	---

System Name: Gates, City of

Entry Point: EP-A

Sample Period: July 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.30	
Alk	19	(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

Print Name: Gregory R Benthin

Signature: *Gregory R Benthin*

Date: 8/2/2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**