

Day	pH	Alk	Phos	Other	Y/N
1	8.37				Y
2	8.28				Y
3	8.35				Y
4	8.45	24			Y
5	Off				Off
6	8.42				Y
7	8.50				Y
8	8.43				Y
9	Off				Off
10	8.47				Y
11	8.29				Y
12	8.50				Y
13	Off				Off
14	8.25				Y
15	8.41				Y
16	8.42	26			Y
17	8.29				Y
18	8.24				Y
19	8.11				Y
20	8.24				Y
21	7.97	28			Y
22	8.25				Y
23	Off				Off
24	8.28				Y
25					Off
26	8.27				Y
27					Off
28	8.23	30			Y
29					Off
30	8.25				Y
31					Off
					0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

0	0	3	1	7
---	---	---	---	---

System Name: Gates, City of

Entry Point: EP-A

Sample Period: August 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.30

Alk

19

(Alkalinity)

PO4

--

(Orthophosphate)

Other

--

(_____)

Print Name: Gregory R Benthin

Signature: *Gregory R Benthin*

Date: 9/6/2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**