

**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	8.28				Y
2					Off
3	8.39				Y
4					Off
5	8.37				Y
6		26			Off
7					Off
8	8.42				Y
9					Off
10					Off
11	8.29	30			Y
12	8.14				Y
13	8.20				Y
14					Off
15	8.13	26			
16					Off
17	8.35				Y
18	8.14				Y
19					Off
20	7.98				Y
21	8.00	26			Y
22	8.33				Y
23					Off
24	8.27				Y
25					
26					Off
27	8.25	26			Y
28					Off
29					Off
30					8.17
31					

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 

0	0	3	1	7
---	---	---	---	---

**System Name:** Gates, City of

**Entry Point:** EP-A

**Sample Period:** September 2023  
Month/Year

**Number of excursions\* during this month: 0**  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months: 0**  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 

7.30
------

Alk 

19
----

 (Alkalinity)

PO4 

--

 (Orthophosphate)

Other 

--

 (\_\_\_\_\_)

**Print Name:** Gregory R Benthin

**Signature:** *Gregory R Benthin*

**Date:** October 2, 2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** | 0