

Day	pH	Alk	Phos	Other	Y/N
1					Off
2					Off
3	8.32				Y
4					Off
5					Off
6	8.34	24			Y
7					Off
8					Off
9	8.36				Y
10					Off
11					Off
12	8.32				Y
13	8.42				Y
14					Off
15	8.35				Y
16					Off
17					Off
18	8.39	30			Y
19					Off
20					Off
21	8.58				Y
22					Off
23					Off
24	8.45				Y
25					Off
26					Off
27	8.48				Y
28					Off
29					Off
30	8.57				Y
31					Off
					N

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 

0	0	3	1	7
---	---	---	---	---

System Name: Gates, City of

Entry Point: EP-A

Sample Period :October 2023  
*Month/Year*

Number of excursions\* during this month: 0  
*(Count the number of days when any WQP was less than the minimum required)*

Total excursions during the previous 5 months: 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 

7.30
------

  
Alk 

19
----

*(Alkalinity)*  
PO4 

--

*(Orthophosphate)*  
Other 

--

*(\_\_\_\_\_)*

Print Name: Gregory R Benthin

Signature: *Gregory R Benthin*

Date: 11/1/2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**