

Day	pH	Alk	Phos	Other	Y/N
1		26			Off
2	8.58				Y
3					Off
4					Off
5	8.59				Y
6					Off
7					Off
8	8.52				Y
9	8.09				Y
10					Off
11					Off
12	8.57				Y
13		30			Off
14					Off
15	8.50				Y
16					Off
17					Off
18	8.64				Y
19					Off
20					Off
21	8.47				Y
22					Off
23					Off
24	8.47	24			Y
25					Off
26					Off
27	8.41				Y
28					Off
29					Off
30	8.36				Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

0	0	3	1	7
---	---	---	---	---

System Name: Gates, City of

Entry Point: EP-A

Sample Period : November- 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.30

Alk

19

(Alkalinity)

PO4

--

(Orthophosphate)

Other

--

(_____)

Print Name: Gregory R Benthin

Signature: *Gregory R Benthin*

Date: 12/4/23

Send to DWP within 10 days after end of sampling period