

Day	pH	Alk	Phos	Other	Y/N
1					Off
2					Off
3	8.38				Y
4					Off
5					Off
6	8.17	24			Y
7					Off
8	8.13				Y
9					Off
10					Off
11	8.30				Y
12	8.05				Y
13					Off
14	8.31				Y
15					Off
16					Off
17	8:20				Y
18					Off
19					Off
20	8.25	28			Y
21					Off
22					Off
23	8.34				Y
24					Off
25					Off
26	8.34				Y
27					Off
28					Off
29	8.37	30			Y
30					Off
31					Off
					0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

0	0	3	1	7
---	---	---	---	---

System Name: Gates, City of

Entry Point: EP-A

Sample Period : December- 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.30

Alk

19

(Alkalinity)

PO4

--

(Orthophosphate)

Other

--

(_____)

Print Name: Gregory R Benthin

Signature: *Gregory R Benthin*

Date: 1/2/24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**