

Day	pH	Alk	Phos	Other	Y/N
1					Off
2					Off
3	8.38				Y
4					Off
5		20			Off
6	8.38				Y
7		22			Off
8					Off
9	8.43				Y
10					Off
11					Off
12	8.52				Y
13					Off
14					Off
15	8.42	24			Y
16					Off
17					Off
18	8.53				Y
19					Off
20					Off
21	8.50				Y
22					Off
23					Off
24	8.46				Y
25	8.41				Y
26		28			Off
27					Off
28	8.37				Y
29	8.32				Y
					0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

0	0	3	1	7
---	---	---	---	---

System Name: Gates, City of

Entry Point: EP-A

Sample Period February 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.30

Alk

19

(Alkalinity)

PO4

--

(Orthophosphate)

Other

--

(_____)

Print Name: Gregory R Benthin

Signature: *Gregory R Benthin*

Date: 3/1/2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's