

Day	pH	Alk	Phos	Other	Y/N
1	8.54				Y
2					Off
3					Off
4	8.51	24			Y
5					Off
6					Off
7	8.48				Y
8					Off
9					Off
10	8.61				Y
11		20			Off
12					Off
13	8.57				Y
14					Off
15					Off
16	8.67				Y
17					Off
18					Off
19	8.64				Y
20					Off
21					Off
22	8.65	24			Y
23					Off
24					Off
25	8.65	20			Y
26					Off
27					Off
28	8.66				Y
29					Off
30					Off
31	8.77				Y
					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	3	1	7
---	---	---	---	---

System Name: Gates, City of

Entry Point: EP-A

Sample Period March 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<table border="1"><tr><td>7.30</td></tr></table>	7.30	
7.30			
Alk	<table border="1"><tr><td>19</td></tr></table>	19	<i>(Alkalinity)</i>
19			
PO4	<table border="1"><tr><td></td></tr></table>		<i>(Orthophosphate)</i>
Other	<table border="1"><tr><td></td></tr></table>		<i>(_____)</i>

Print Name: Gregory R Benthin

Signature: *Gregory R Benthin*

Date: 4/4/2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**