

Day	pH	Alk	Phos	Other	Y/N
1					Off
2					Off
3	8.85				Y
4	8.73				Y
5					Off
6	8.67				Y
7					Off
8					Off
9	8.59				Y
10					Off
11					Off
12	8.80	22			Y
13					Off
14					Off
15	8.72				Y
16					Off
17					Off
18	8.81	20			Y
19					Off
20					Off
21	8.84				Y
22	8.50				Y
23					Off
24	8.69				Y
25		26			Off
26					Off
27	8.82				Y
28					Off
29					Off
30	8.81				Y
					0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

0	0	3	1	7
---	---	---	---	---

System Name: Gates, City of

Entry Point: EP-A

Sample Period April 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.30

Alk

19

(Alkalinity)

PO4

--

(Orthophosphate)

Other

--

(_____)

Print Name: Gregory R Benthin

Signature: *Gregory R Benthin*

Date: 5/2/2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's