

Day	pH	Alk	Phos	Other	Y/N
1	8.86				Y
2					Off
3					Off
4	8.55	26			Y
5					Off
6					Off
7	8.67				Y
8					Off
9	8.76				Y
10		24			Off
11	8.41				Y
12					Off
13					Off
14	8.82				Y
15					Off
16					Off
17	8.76	22			Y
18					Off
19	8.79				Y
20					Off
21	8.69				Y
22					Off
23	8.65				
24					Off
25	8.52	24			Y
26					Off
27	8.91				Y
28					Off
29	8.81				Y
30					Off
31					
					0

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 

0	0	3	1	7
---	---	---	---	---

System Name: Gates, City of

Entry Point: EP-A

Sample Period June-2024  
*Month/Year*

Number of excursions\* during this month: 0  
*(Count the number of days when any WQP was less than the minimum required)*

Total excursions during the previous 5 months: 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 

7.30
------

  
Alk 

19
----

*(Alkalinity)*  
PO4 

--

*(Orthophosphate)*  
Other 

--

*(\_\_\_\_\_)*

Print Name: Gregory R Benthin

Signature: *Gregory R Benthin*

Date: 7/1/2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's