

Day	pH	Alk	Phos	Other
1	8.67			
2	Off			
3	8.67			
4	Off			
5	8.75			
6	Off			
7	8.46			
8	8.60	26		
9	8.49			
10	8.44			
11	8.47			
12	7.98			
13	Off			
14	8.35			
15	8.08			
16	8.37			
17	Off			
18	8.32	30		
19	7.96			
20	8.16			
21	7.91			
22	8.19			
23	Off			
24	8.15	22		
25	Off			
26	8.06			
27	Off			
28	7.87			
29	7.93			
30	8.06			
31	Off			

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 

0	0	3	1	7
---	---	---	---	---

System Name: Gates, City of

Entry Point: EP-A

Sample Period July-2024  
*Month/Year*

Number of excursions\* during this month: 0  
*(Count the number of days when any WQP was less than the minimum required)*

Total excursions during the previous 5 months: 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 

7.30
------

  
Alk 

19
----

*(Alkalinity)*  
PO4 

--

*(Orthophosphate)*  
Other 

--

*(\_\_\_\_\_)*

Print Name: Gregory R Benthin

Signature: *Gregory R Benthin*

Date: 8/6/2024

Send to DWP within 10 days after end of sampling period

0

(No = N = Excursion) **Total N's**