

Day	pH	Alk	Phos	Other	Y/N
1	8.13				Y
2	7.94				Y
3	Off				
4	8.14				Y
5	7.78				Y
6	Off				
7	7.93				Y
8	7.84				Y
9	Off				
10	8.02	30			Y
11	Off				
12	8.08	24			Y
13	7.82				Y
14	7.72				Y
15	Off				
16	8.05				Y
17	Off				
18	8.04				Y
19	7.86				Y
20	8.05				Y
21	8.06	21			
22	Off				
23	7.95				Y
24	Off				
25	7.64				Y
26	7.54				Y
27	7.59				Y
28	Off				
29	7.77				Y
30	Off				Y
31	7.91				Y
					0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

0	0	3	1	7
---	---	---	---	---

System Name: Gates, City of

Entry Point: EP-A

Sample Period August-2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.30

Alk

19

 (Alkalinity)

PO4

--

 (Orthophosphate)

Other

--

 (_____)

Print Name: Gregory R Benthin

Signature: *Gregory R Benthin*

Date: 9/3/2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**