

Day	pH	Alk	Phos	Other	Y/N
1	7.69	26			Y
2	Off				
3	Off				
4	7.68				Y
5	Off	22			
6	Off				
7	7.68				Y
8	Off				
9	Off				
10	7.67				Y
11	Off				
12	Off				
13	7.68				Y
14	Off	24			
15	Off				
16	7.69				Y
17	Off				
18	Off				
19	7.68				Y
20	Off				
21	Off				
22	7.71				Y
23	Off				
24	Off				
25	7.69	22			Y
26	Off				
27	Off				
28	7.69				Y
29	Off				
30	Off				
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	3	1	7
---	---	---	---	---

System Name: Gates, City of

Entry Point: EP-A

Sample Period: November 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.30

Alk

19

(Alkalinity)

PO4

--

(Orthophosphate)

Other

--

(_____)

Print Name: Gregory R Benthin

Signature: *Gregory R Benthin*

Date: 12/3/2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**

0
