

Day	pH	Alk	Phos	Other	Y/N
1	Off				
2	7.67				Y
3	Off				
4	Off				
5	7.10				Y
6	Off				
7	Off				
8	7.73	24			Y
9	Off				
10	Off				
11	7.81				Y
12	Off				
13	Off				
14	7.82	20			Y
15	Off				
16	Off				
17	7.87	24			Y
18	Off				
19	Off				
20	7.98				Y
21	Off				
22	Off				
23	7.99				Y
24	7.64				Y
25	Off				
26	7.95				Y
27	7.83	22			Y
28	Off				
29	8.04	24			Y
30	Off				
31	Off				
					0

(No = N = Excursion) **Total N's**

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0	0	3	1	7
---	---	---	---	---

System Name: Gates, City of

Entry Point: EP-A

Sample Period: January/2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.30	
Alk	19	(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: Gregory R Benthin

Signature: Gregory R Benthin

Date: 2/5/2025

Send to DWP within 10 days after end of sampling period