

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos	Other	Y/N
1	7.81				Y
2	Off				
3	Off				
4	8.18	24			Y
5	Off				
6	Off				
7	8.28				Y
8	Off				
9	Off				
10	8.17				Y
11	Off	28			
12	Off				
13	8.28				Y
14	Off				
15	7.69				Y
16	Off				
17	Off				
18	8.45	24			Y
19	8.08				Y
20	Off				
21	8.44				Y
22	Off				
23	Off				
24	8.62	24			Y
25	Off				
26	8.58				Ys
27	Off				
28	Off				
3.					0

(No = N = Excursion) Total N's

< <have minimums<="" th=""><th colspan="4">ENTRY POINT</th></have>	ENTRY POINT					
been met for this day?	PWS ID: 41 0 0 3 1 7					
System Name: <u>Gates, City of</u>						
Entry Point: EP-A						
Sample Period: Feb-2025						
	Month/Year					

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

Minimum Water Quality Parameters as set by					
pН	7.30				
Alk	19	(Alkalinity)			
PO4		(Orthophosphate)			
Other		()			
		-			

Print Name:	Gregory R Benthin				
Signature:	Inga R Berth				
Date: 3/5/25					
Send to DWP within 10 days after end of					

sampling period