

Day	pH	Alk	Phos	Other	Y/N
1	8.54				Y
2	Off				
3	Off				
4	8.39	22			Y
5	Off				
6	Off				
7	8.41				Y
8	Off				
9	Off				
10	8.36	22			Y
11	8.20				Y
12	Off				
13	8.37				Y
14	Off				
15	Off				
16	8.35				Y
17	8.35	20			Y
18	Off				
19	Off				
20	8.43				Y
21	8.19				Y
22	Off				
23	8.15				Y
24	Off	28			
25	Off				
26	8.14				Y
27	Off				
28	Off				
29	8.36				Y
30	Off				
31	Off	20			
					0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0	0	3	1	7
---	---	---	---	---

System Name: Gates, City of

Entry Point: EP-A

Sample Period: March-2025

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.30

Alk 19 (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: Gregory R Benthin

Signature: Gregory R Benthin

Date: April 7, 2025

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's