

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.33	21			Y
2	Off				
3	7.81				Y
4	Off				
5	8.02				Y
6	Off				
7	7.83	22			Y
8	Off				
9	7.91				Y
10	Off				
11	8.05				Y
12	Off				
13	Off	24			
14	7.88				Y
15	Off				
16	Off				
17	7.83				Y
18	Off				
19	7.85	24			Y
20	7.83				Y
21	Off				
22	7.79				Y
23	Off				
24	8.14				Y
25	Off				
26	8.05				Y
27	Off	22			
28	7.80				Y
29	7.95				Y
30	7.92				Y
31					
					0

<<Have **ENTRY POINT**
minimums
been met for **PWS ID: 41**

0	0	3	1	7
---	---	---	---	---

this day?

System Name: Gates, City of

Entry Point: EP-A

Sample Period: May-2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.30

Alk

19

 (Alkalinity)
PO4

--

 (Orthophosphate)
Other

--

 ()

Print Name: Gregory R Benthin

Signature: Gregory R Benthin

Date: 9/9/2025

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**