

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.05				Y
2	7.93				Y
3	7.80	24			Y
4	Off				
5	7.93				Y
6	7.99				Y
7	7.95				Y
8	7.87				Y
9	7.54	24			Y
10	7.58				Y
11	7.81				Y
12	8.04				Y
13	Off				Y
14	8.05				Y
15	Off				
16	8.10	24			Y
17	7.89				Y
18	7.76				Y
19	7.70				Y
20	8.04				Y
21	7.85				Y
22	Off				
23	8.09	24			Y
24	Off				
25	7.97				Y
26	7.97				Y
27	7.78				Y
28	7.77				Y
29	7.64				Y
30	7.62				Y
31					
					0

(No = N = Excursion) Total N's

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0	0	3	1	7
---	---	---	---	---

System Name: Gates, City ofEntry Point: EP-ASample Period: June-2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality
Parameters as set bypH 7.30Alk 19 (Alkalinity)PO4 (Orthophosphate)Other ()Print Name: Gregory R BenthinSignature: Gregory R BenthinDate: 7/8/2025Send to DWP within 10 days after end of
sampling period