

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.62				Y
2	7.60				Y
3	7.63	21			Y
4	7.65				Y
5	7.65				Y
6	7.60				Y
7	7.79	24			Y
8	7.69				Y
9	Off				
10	8.10				Y
11	7.84				Y
12	8.06				Y
13	Off				
14	7.64				Y
15	7.91				Y
16	8.12				Y
17	7.71	24			Y
18	7.78				Y
19	7.98				Y
20	8.17				Y
21	7.88				Y
22	7.97				Y
23	8.01	20			Y
24	7.89				Y
25	8.04				Y
26	8.17				Y
27	7.72				Y
28	7.69	20			Y
29	7.83				Y
30	8.10				Y
31	Off				
					0

(No = N = Excursion) **Total N's**

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0	0	3	1	7
---	---	---	---	---

System Name: Gates, City of

Entry Point: EP-A

Sample Period: July-2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH

7.30

Alk

19

 (Alkalinity)
PO4

--

 (Orthophosphate)
Other

--

 ()

Print Name: Gregory R Benthin

Signature: Gregory R Benthin

Date: 8/4/2025

Send to DWP within 10 days after end of sampling period