

## Water Quality Parameter Monitoring Form

## **Lead & Copper Rule Corrosion Control**

Day	рН	Alk	Phos	Other	Y/N
1	8.15				Y
2	8.34				Y
3	8.04				Y
4	7.93	20			Y
5	7.94				Y
6	7.82				Y
7	7.61				Y
8	7.55				Y
9	7.70				Y
10	7.63				Y
11	8.01	22			Y
12	7.63				Y
13	7.69				Y
14	7.79				Y
15	7.69				Y
16	7.66				Y
17	8.03				Y
18	7.73				Y
19	7.93				Y
20	Off				
21	8.02	24			Y
22	7.95				Y
23	Off				
24	8.04				Y
25	7.69				Y
26	7.64				Y
27	7.80				Y
28	7.78	22			Y
29	7.69				Y
30	7.79				Y
31	7.99				Y
					0

< <have minimums<="" th=""><th><b>ENTRY POINT</b></th></have>	<b>ENTRY POINT</b>
been met for this day?	<b>PWS ID: 41</b> 0 0 3 1 7
System	Name: Gates, City of
Entry Po	int: EP-A
Sample	Period: August-2025
	Month/Year
Number of e	xcursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

		Water Quality s as set by
рН	7.30	
Alk	19	(Alkalinity)
PO4		(Orthophosphate)
Other		(

	ure: Shap R Benthin
Date:	9/03/2025
	o DWP within 10 days after end of ng period