

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.80				Y
2	7.90				Y
3	7.69	24			Y
4	7.63				Y
5	7.66				Y
6	Off				
7	7.64				Y
8	7.80				Y
9	7.65	22			Y
10	Off				
11	7.72				Y
12	Off				
13	7.75				Y
14	7.59				Y
15	7.56	22			Y
16	Off				
17	7.58				Y
18	7.15				Y
19	7.68				Y
20	7.60				Y
21	7.59				Y
22	7.43				Y
23	7.52	20			Y
24	7.55				Y
25	Off				
26	7.88				Y
27	Off				
28	7.98				Y
29	Off				
30	7.90	22			Y
31					
					0

(No = N = Excursion) Total N's

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0	0	3	1	7
---	---	---	---	---

System Name: Gates, City of

Entry Point: EP-A

Sample Period: September-2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH 7.30

Alk 19 (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: Gregory R Benthin

Signature: Gregory R Benthin

Date: 10/2/2025

Send to DWP within 10 days after end of
sampling period