

Day	pH	Alk	Phos	Other	Y/N
1	7.86				Y
2	Off				
3	7.73	22			Y
4	Off				
5	Off				
6	7.84				Y
7	7.81				Y
8	Off				
9	7.79				Y
10	7.84	22			Y
11	Off				
12	7.88				Y
13	Off				
14	Off				
15	7.90				Y
16	7.76				Y
17	Off				
18	Off	24			
19	7.90				Y
20	Off				
21	7.85				Y
22	Off				
23	Off				
24	7.88	26			Y
25	Off				
26	7.81				Y
27	Off				
28	7.56				Y
29	Off				
30	Off				
31					

(No = N = Excursion) **Total N's**

<<Have  
minimums  
been met for  
this day?

### ENTRY POINT

PWS ID: 41

0 | 0 | 3 | 1 | 7

System Name: Gates, City of

Entry Point: EP-A

Sample Period: November-2025

Month/Year

**Number of excursions\* during this month: 0**

*(Count the number of days when any WQP was  
less than the minimum required)*

**Total excursions during the previous 5 months: 0**

*(Over 9 excursions in 6 months is a violation. Entry  
Point and Distribution excursions are cumulative )*

For OHA use only

Minimum Water Quality  
Parameters as set by

pH 7.30

Alk 19

(Alkalinity)

PO4

(Orthophosphate)

Other

(\_\_\_\_\_)

Print Name: Gregory R Benthin

Signature: Gregory R Benthin

Date: 12/2/2025

Send to DWP within 10 days after end of  
sampling period