

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.80				Y
2	7.72	24			Y
3	Off				
4	7.76				Y
5	7.77				Y
6	Off				
7	7.68				Y
8	Off				
9	7.60				Y
10	Off				
11	7.29	24			Y
12	Off				
13	Off				
14	7.57				Y
15	Off				
16	Off				
17	7.69				Y
18	7.67	28			Y
19	7.34				Y
20	Off				
21	7.55				Y
22	Off				
23	7.57				Y
24	Off				
25	Off				
26	7.67				Y
27	Off				
28	7.71				Y
29	Off	26			
30	7.73				Y
31					
					0

(No = N = Excursion) **Total N's**

<<Have  
minimums  
been met for  
this day?

**ENTRY POINT**

PWS ID: 41

0	0	3	1	7
---	---	---	---	---

**System Name:** Gates, City of

**Entry Point:** \_\_\_\_\_

**Sample Period:** December 2025

Month/Year

**Number of excursions\* during this month: 0**  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months: 0**  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality  
Parameters as set by**

pH	7.30	
Alk	19	(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

**Print Name:** Gregory R Benthin

**Signature:** Gregory R Benthin

**Date:** 1/05/2026

Send to DWP within 10 days after end of sampling period