

Day	pH	Alk	Phos	Other	Y/N
1	7.70				Y
2	7.78				Y
3	7.87				Y
4	Off				
5	7.79	20			Y
6	7.70				Y
7	Off				
8	7.88				Y
9	Off				
10	7.75				Y
11	7.70	22			Y
12	7.72				Y
13	Off				
14	7.70				Y
15	Off				
16	7.76				Y
17	Off				
18	Off				
19	Off				
20	7.80	22			Y
21	7.73				Y
22	7.70				Y
23	Off				
24	7.88				Y
25	Off				
26	7.76	20			Y
27	7.77				Y
28	Off				
29	7.76				Y
30	7.74				Y
31	Off				
					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	3	1	7
---	---	---	---	---

System Name: City of Gates

Entry Point: A

Sample Period: January 2026
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.3

 Alk

19.0

(Alkalinity)
 PO4

--

(Orthophosphate)
 Other

--

(_____)

Print Name: Gregory R Benthin

Signature: *Gregory R Benthin*

Date: 2/04/26

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**